

Detailed Latest Test Results Harrison (P.A.T) Services

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 24/03/2010 To: 24/03/2010

Site: SAMPLE COMPANY **Location: ROOM 9**

Asset ID: D01 Description: EXTENSION 3W User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	<0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D02 Description: EXTENSION 2W User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.07	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D03 Description: LAMP User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Site: SAMPLE COMPANY **Location: ROOM 8**

Asset ID: D04 Description: KETTLE User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.06	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D05 Description: TELEVISION IEC User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.05	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D06 Description: TELEVISION PSU User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.09	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D07 Description: EXTENSION 4W User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.07	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D08 Description: EXTENSION 2W User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.08	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Detailed Latest Test Results Harrison (P.A.T) Services

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 24/03/2010 To: 24/03/2010

Asset ID: D09	Description: LAMP	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Asset ID: D10	Description: SIGNAL BOOSTER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Site: SAMPLE COMPANY	Location: ROOM 7		
Asset ID: D11	Description: EXTENSION 4W	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.05	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Polarity	24/03/2010		Pass
Overall: Pass			

Asset ID: D12	Description: KETTLE	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.05	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Asset ID: D13	Description: TELEVISION IEC	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.05	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Polarity	24/03/2010		Pass
Overall: Pass			

Asset ID: D14	Description: TELEVISION PSU	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.09	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Site: SAMPLE COMPANY	Location: ROOM 6		
Asset ID: D15	Description: EXTENSION 4W	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.04	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Polarity	24/03/2010		Pass
Overall: Pass			

Asset ID: D16	Description: EXTENSION 2W	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.08	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Polarity	24/03/2010		Pass
Overall: Pass			

Asset ID: D17	Description: EXTENSION 1W	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.07	Ohm Pass

Detailed Latest Test Results Harrison (P.A.T) Services

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 24/03/2010 To: 24/03/2010

Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D18	Description: TELEVISION IEC	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D19	Description: TELEVISION	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.06	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D20	Description: SIGNAL BOOSTER	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D21	Description: LAMP	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D22	Description: LAMP	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D23	Description: KETTLE	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Site: SAMPLE COMPANY **Location: ROOM 4**

Asset ID: D24	Description: EXTENSION 4W	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D25	Description: TELEVISION IEC	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.05	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D26	Description: TELEVISION PSU	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.08	Ohm	Pass

Detailed Latest Test Results Harrison (P.A.T) Services

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 24/03/2010 To: 24/03/2010

Insulation 24/03/2010 >99.99 MOhm Pass
Overall: Pass

Asset ID: D27 Description: KETTLE User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.05	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Site: SAMPLE COMPANY Location: ROOM 3

Asset ID: D28 Description: EXTENSION 2W User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	<0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D29 Description: EXTENSION 2W User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.07	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D30 Description: TELEVISION IEC User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D31 Description: TELEVISION User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.06	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D32 Description: KETTLE User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	<0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D33 Description: SIGNAL BOOSTER User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Site: SAMPLE COMPANY Location: ROOM 5

Asset ID: D34 Description: DYSON CLEANER User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D35 Description: IRON User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass

Detailed Latest Test Results Harrison (P.A.T) Services

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 24/03/2010 To: 24/03/2010

Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.05	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Site: SAMPLE COMPANY Location: ROOM 1

Asset ID: D36 Description: EXTENSION 4W User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	<0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D37 Description: LAMP User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D38 Description: LAMP User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D39 Description: TELEVISION IEC User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D40 Description: EXTENSION 4W User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	<0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Polarity	24/03/2010			Pass

Overall: Pass

Asset ID: D41 Description: KETTLE User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	<0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D42 Description: TELEVISION User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.06	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Site: SAMPLE COMPANY Location: HALL

Asset ID: D43 Description: LAMP User: BRYAN Test Instrument: 22A-0168

Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Detailed Latest Test Results Harrison (P.A.T) Services

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 24/03/2010 To: 24/03/2010

Site: SAMPLE COMPANY **Location: KITCHEN**

Asset ID: D44	Description: KETTLE	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.04	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Asset ID: D45	Description: TOASTER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	<0.04	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Asset ID: D46	Description: TOASTER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	<0.04	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Asset ID: D47	Description: BOILER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.15	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Asset ID: D48	Description: TEA URN IEC	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.04	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Polarity	24/03/2010		Pass
Overall: Pass			

Asset ID: D49	Description: TEA URN	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.06	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Asset ID: D50	Description: EXTENSION 6W	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	<0.04	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Polarity	24/03/2010		Pass
Overall: Pass			

Asset ID: D51	Description: MICROWAVE	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	<0.04	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass
Overall: Pass			

Asset ID: D52	Description: FRIDGE FREEZER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information

Detailed Latest Test Results Harrison (P.A.T) Services

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 24/03/2010 To: 24/03/2010

Earth	24/03/2010	0.07	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: D53	Description: EXTENSION 2W	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.05	Ohm Pass
Insulation	24/03/2010	46.4	MOhm Pass
Polarity	24/03/2010		Pass

Overall: Pass

Asset ID: D54	Description: COOKER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.05	Ohm Pass
Insulation	24/03/2010	31.03	MOhm Pass

Overall: Pass

Asset ID: D55	Description: COOKER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.05	Ohm Pass
Insulation	24/03/2010	21.32	MOhm Pass

Overall: Pass

Asset ID: D56	Description: DISHWASHER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.06	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass

Overall: Pass

Asset ID: D57	Description: WASHING MACHINE	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.04	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass

Overall: Pass

Asset ID: D58	Description: CHEST FREEZER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.08	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass

Overall: Pass

Asset ID: D59	Description: TUMBLE DRYER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.05	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass

Overall: Pass

Asset ID: D60	Description: TUMBLE DRYER	User: BRYAN	Test Instrument: 22A-0168
Test Type	Date	Result	Unit Status
Visual	24/03/2010		Pass
Earth Current	24/03/2010	25	A Information
Earth	24/03/2010	0.04	Ohm Pass
Insulation	24/03/2010	>99.99	MOhm Pass

Overall: Pass

Detailed Latest Test Results Harrison (P.A.T) Services

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 24/03/2010 To: 24/03/2010

Asset ID: D61	Description: WASHING MACHINE	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Overall: Pass				

Site: SAMPLE COMPANY	Location: DINING ROOM			
Asset ID: D62	Description: ELECTRIC FIRE	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Earth Current	24/03/2010	25	A	Information
Earth	24/03/2010	0.04	Ohm	Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: D63	Description: RADIO PSU	User: BRYAN	Test Instrument: 22A-0168	
Test Type	Date	Result	Unit	Status
Visual	24/03/2010			Pass
Insulation	24/03/2010	>99.99	MOhm	Pass
Overall: Pass				

Total Tests: 63